

CERTIFICATE OF COMPLIANCE

Certificate Number 20130320-E72776
Report Reference E72776-20100501
Issue Date 2013-MARCH-20

Issued to: BAECHLI AG
RAINACHERSTRASSE 12
6012 OBERNAU SWITZERLAND

This is to certify that representative samples of TRANSFORMERS, GENERAL PURPOSE
Please refer to Addendum page for models


Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 5085-1 - LOW VOLTAGE TRANSFORMERS - PART 1:
GENERAL REQUIREMENTS
UL 5085-2 LOW VOLTAGE TRANSFORMERS - PART 2:
GENERAL PURPOSE TRANSFORMERS
CSA-C22.2 No. 66.1 - Low Voltage Transformers - Part 1:
General Requirements
CSA-C22.2 No. 66.2 - Low Voltage Transformers - Part 2:
General Purpose Transformers

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and

"US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130320-E72776
Report Reference E72776-20100501
Issue Date 2013-MARCH-20

Transformer, Series GS x, GT x, single phase types. Isolation transformers

The series GS x and GT x can be provided with max. 3 primary windings in summary not exceeding 600V and can have up to max. 6 secondary windings in summary not exceeding 600V

Transformer, Series SG x, single phase types. Autotransformer

Transformer, Series GM x, single three phase transformers or having min. one isolated output and min. one autotransformer output

Where x indicates the max. power in VA of the transformer and could be max. 3.6, 4.5, 6, 12, 23, 45, 64, 131, 200, 160, 315, 550, 310, 580, 540, 1270, 980, 1400, 1740, 2220, 3170, 2910 or 4870 for EI sized core types and 8, 33, 70, 179, 410, 805, 1200, 1710, 2240, 2650, 4830, 5240, 6190, 9900, 25000 or 31500 for UI core sized types



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

