

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20130320-E72776  
**Report Reference** E72776-20100430  
**Issue Date** 2013-MARCH-20

**Issued to:** BAECHLI AG  
RAINACHERSTRASSE 12  
6012 OBERNAU SWITZERLAND

**This is to certify that representative samples of** TRANSFORMERS, GENERAL PURPOSE  
Please refer to Addendum page for models


Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 5085-1 - LOW VOLTAGE TRANSFORMERS - PART 1:  
GENERAL REQUIREMENTS  
UL 5085-2 LOW VOLTAGE TRANSFORMERS - PART 2:  
GENERAL PURPOSE TRANSFORMERS  
CSA-C22.2 No. 66.1 - Low Voltage Transformers - Part 1:  
General Requirements  
CSA-C22.2 No. 66.2 - Low Voltage Transformers - Part 2:  
General Purpose Transformers

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and

"US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20130320-E72776  
**Report Reference** E72776-20100430  
**Issue Date** 2013-MARCH-20

Transformer, Series DGS x, DGT x, three phase types. Isolation transformers

The series DGS x and DGT x can be provided with max. 3 primary windings in summary not exceeding 600V and can have up to max. 6 secondary windings in summary not exceeding 600V

Transformer, Series DSG x, Three phase types. Autotransformer

Transformer, Series DMG x, three phase transformers or having min. one isolated output and min. one autotransformer output

Where x indicates the max. power in VA of the transformer and could be max. 13, 43, 101, 233, 535, 1000, 1555, 1630, 2280, 3010, 3655, 5970, 6970, 8860, 14300, 33500, 51000, 56900, 95000, 90000 or 100000

NOTE: All models may be prefixed by the letter "B" for branding purposes.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

